



CROSS SECTION 'B'


WALL HAS SLOPE OF M=17.33mm [0.7]




CROSS SECTION 'A'



PLAN VIEW (PAD)



PLAN VIEW (BASE)



ISOMETRIC VIEW

ALL DIMENSIONS DEFAULT TO MILLIMETERS

mm [in.]



61 BONGARD AVE
OTTAWA, ON,
PH: 800.267.6466
FAX: 613.225.1681

www.utilitystructures.com

NOTES:

DESIGNED TO CL-625-ONT TRUCK LIVE LOADING AS PER CSA S6-06

*CSA 23.4-05
35MPa (5000psi) AT 28 DAYS
6-8% AIR ENTRAINED

REV.#	MM/DD/YYYY	PREP.
1	OCT/09/2008	LRW
2	FEB/26/2009	LRW

E-60^C / E-61_w
ELECTRICAL MANHOLE BASE AND PAD

WEIGHT = 3295kg/7475lbs

1.56m(H) x 1295mm x 1295mm