

#### BASE BURIAL DEPTH SUBJECT TO SOIL CONDITIONS, REFER TO SOIL REPORT. THE POLE BASE DESIGN IS BASED ON THE ASSUMPTION THAT THE MINIMUM SOIL BEARING CAPACITY IS 150KPa AT sls AND 225KPa AT ULS.

**BASE** 

**BURIAL** 

**DEPTH** 

(ft.)

5'

6'

7'

8'

**OVERALL** 

**LENGTH** 

"X"

(ft.)

5'6"

6'6'

7'6"

8'6'

WEIGHT

(kg/lbs.)

700kg / 1,540lbs

800kg / 1,760lbs

900kg / 1.980lbs

1000kg / 2,200lbs

**POLE** 

**HEIGHT** 

(ft.)


6-11

12-17

18-24

25-30

#### **PLAN VIEW**



## **SIDE ELEVATION**

[Inches]
ALL DIMENSIONS DEFAULT TO MILLIMETRES



## UTILITY STRUCTURES INC.

61 BONGARD AVE | OTTAWA, ON | K2E 6V2 T: 613.225.6398 F: 613.225.1681 TF: 800.267.6466

www.utilitystructures.com

#### **CONSTRUCTION DETAILS:**

- ACCOMMODATES VARIOUS POLE HEIGHTS
- ADJUSTABLE BOLT CIRCLE DIAMETER
- BOLT CIRCLE DIAMETER: 150mm[6"] TO 305mm[12"]

# • CSA 23.4-05

- 45 MPa (6525psi) AT 28 DAYS
- STRIPPING STRENGTH: MIN. 20 MPa(2900psi)
- **5-8% AIR ENTRAINED**
- **EXPOSURE CLASS: C-1**
- REINFORCING: STEEL TO CSA CAN A23.1

**ISOMETRIC VIEW** 

18" DIA. DECORATIVE ROUND POLE BASE

VARIES(H) X 457mm dia.

TOTAL WEIGHT:

**VARIES** 

REVISION DATE: MAY 19, 2017

**REV.** #1